



IMPORTANT

Remove jumper between terminal I & C before connecting interlocks. Wire in accordance with local & National Electrical codes. Read instructions carefully before wiring and operating.

Frame shown in heavy line represents Thermolec Electric Coil. All wiring outside this frame are "typical external wiring by others".

LEGEND

- A Automatic Reset Cut Out
- C1,C2 Operating Contactors
- CM Back-up Contactor to Manual
- DISC Disconnect Switch
- D35 Solid State Controller
- F Fuse Or Fuse Link
- M Manual Reset Cut Out
- PDS Pressure Differential Switch
- R Relay
- SSR Solid State Relay
- T Control Circuit Transformer